# **BOKARO POWER SUPPLY CO. (P) LTD.**

# HALL NO:- M-01, OLD ADMINISTRATIVE BUILDING, ISPAT BHAVAN, BOKARO STEEL CITY – 827001

CIN:U40300DL2001PTC112074

Reg. Office: Ispat Bhawan, Lodhi Road, New Delhi - 110 003

TENDER NOTICE NO.: BPSCL/CEO/P&C/16-17/C-206/NIT-632/1496 Dated 15/03/2017



NAME OF WORK: Assistance in Maintenance and Repair jobs of Electrical Equipments belonging to LT & HT Indoor Switch Gear area of TPP (including CHP area) of Power Plant

COST: Rs.500/(Rupees Five Hundred only)

# INDEX

Sl.No	Subject	Page No.
1.	Cover Page	1
2.	Index	2
3.	Notice Inviting Tender (with QR)	3-4
4.	<b>Annexure</b> – <b>I</b> (Conditions & Rules to be observed in submitting tenders with online Price Bids)	5-7
5.	Annexure – II (General Terms and Conditions)	8-10
6.	Annexure – III (Scope of work)	11-15
7.	Annexure – IV (Special Terms & Conditions )	16-19
8.	Annexure – V (Schedule of Quantity/ Price Format)	20-21
9.	Annexure – VI (affidavit)	22
10.	Annexure – VII (Checklist)	23
11.	Annexure- VIII (RA Acceptance)	24
12.	Annexure –IX (Declaration after RA)	25
13.	Annexure –X (General EHS responsibility of contractor)	26

# **Bokaro Power Supply Co. (P) Ltd.**

(A Joint Venture of SAIL & DVC)

Hall No: - M-01, Old Administrative Building, Ispat Bhavan, Bokaro Steel City – 827001

#### NOTICE INVITING TENDER

CIN:U40300DL2001PTC112074

Reg. Office: Ispat Bhawan, Lodhi Road, New Delhi - 110 003

Date: 15/03/2017

NIT No.: BPSCL/CEO/P&C/16-17/C-206/NIT-632/1496

For and on behalf of BOKARO POWER SUPPLY COMPANY (P) LTD, sealed tenders in three parts, Part - A : Cost of Tender document & EMD, Part - B : Technical & Commercial Offer and <math>Part - C : Online Price Bid are invited, from reputed, experienced and financially sound firms for the following work at our Power Plant.

Description of Work	Assistance in Maintenance and Repair jobs of Electrical	
	Equipments belonging to LT & HT Indoor Switch Gear	
	area of TPP (including CHP area) of Power Plant	
Earnest Money (in Indian Rs.)	Rs. 15,000/- (Rupees Fifteen Thousand ) only	
Cost of tender documents (Non-refundable) (in Indian Rs.)	Rs.500/- (Rupees Five Hundred) Only	
Period of contract	01 (One) year from the date of commencement of Work. (Extendable	
	for another one (01) year on satisfactory performance)	
Last date & time of submission of tender	17/04/2017 at 12.00 Hrs. (IST)	
Bid opening Date & Time.	17/04/2017 at 12:15 Hrs. (Part A & B)	

#### **Qualifying Requirements / Eligibility Criteria:**

1. The Bidder should be a valid (upto date) ISO: 9001-2008 (or advance) certified company, while submission of tender.

#### 2. Average annual turnover (AAT)

Tenderer should have Minimum average annual turnover (MAT) of Rs.8.00 Lakhs

- ⇒ Average annual turnover shall be determined taking into consideration turnover of available preceding three consecutive financial years. Other income shall not be considered for arriving at annual turnover.
- Audited annual accounts along with auditor's report of the bidder should be furnished in support of the same. Where audited annual account is not mandatory as per the law, the bidder has to submit annual financial turnover during the consecutive last three (03) years, ending 31st March of the previous financial year duly certified by CA.

### 3. Technical Capability:

Party should have experience of having completed **similar works** in any Public Sector Undertaking / Government / Semi Government organization or joint venture thereof / Company registered under Companies Act during last 7 years ending last day of month previous to the one in which offer are invited shall be either of the following:

- Three similar completed works each costing not less than the amount \* equal to **Rs.07.00 lakhs**OR
- Two similar completed works each costing not less than the amount \* equal to **Rs.09.40 lakhs OR**
- ➤ One similar completed work costing not less than the amount \* equal to **Rs.16.40 lakhs**Similar Work means: Assistance in Maintenance / Repair / Overhauling jobs of electrical equipments belonging to LT & HT (6.6 KV or more) switch gears.
- \* The value of work order(s) will be considered on pro rata yearly basis.
- 4. In support of their eligibility and experience, the tenderer is required to submit self attested photo

copies of work orders, completion certificates (by the concerned competent authority etc.) along with the techno-commercial bid. In addition, bidder shall submit an affidavit as per format at **Annexure-VI**, declaring that the documents submitted by them are genuine.

- ⇒ Completed Work means the executed/completed portion of Work Order/AMC/RC, even if the work has not been completed in totality (subject to furnishing proof of executed value of work in the form of certified copies of RA Bills) along with successful work execution certificate (by the concerned authority etc.)
- 5. The bidder shall furnish authenticated copies of latest IT Return, Service Tax Registration, EPF certificate, ESI Certificate.
- 6. The bidder must accept for finalization of rate through Reverse Action (RA), as per format given at Annexure-VIII.

#### **General Terms & Conditions:**

- i) Offer shall be accompanied with Cost of the tender documents of **Rs. 500.00** (non-refundable) in the shape of Demand Draft / Banker's Cheque drawn from any Nationalized / Scheduled Bank except Co-Operative Bank, in favour of **Bokaro Power Supply Company** (**P**) **Ltd.,** Payable at Bokaro Steel City.
  - However Government organizations / Small scale industries registered with NSIC is not required to submit the cost of tender document subject to production of the documentary evidence like valid Registration certificate of the same item or group of item from appropriate Govt. Authority.
- ii) Offer shall be accompanied with Earnest Money Deposit (EMD) of Rs.15,000.00 (Rupees Fifteen thousand) Only in the shape of Demand Draft / Pay Orders / Bankers Cheque Payable at Bokaro Steel City // Bank Guarantee having validity for, one (01) year, from any Nationalized Bank / Scheduled Bank except Co-operative Bank drawn in favour of Bokaro Power Supply Company (P) Ltd. as per format available at our website: <a href="https://www.bpscl.com">www.bpscl.com</a>
- iii) However, Micro & small enterprises (MSEs) / PSU /Govt. Undertakings and Co-operative societies will be exempted from submission of cost of tender document & Earnest Money as per government policy. For MSEs the exemption from paying cost of tender document & Earnest Money will be granted only on submission of valid notarized copy of certificate having a valid Entrepreneurs Memorandum (EM) number.SSI/NSIC certificate holders should also submit a copy of Entrepreneurs Memorandum.
- iv) The undersigned reserves the right to either reject any / all the tenders without assigning any reason thereof & also reserves the right to alter the qualifying requirements.

#### Note:

- 1. Tender documents are to be downloaded from Website: **bpscl.com / eps.buyjunction.in** only.
- 2. Bidders are requested to visit above website regularly for any addendum / corrigendum / Extension till opening of the NIT. **Any such changes shall not be published through Press advt.**

For and on behalf of Bokaro Power Supply Company (P) Limited

(J.M Prasad) DGM (P&C) Tel: 8986874098

Email: purchase.bpscl@gmail.com

# **Conditions & Rules to be observed in submitting Tenders**

#### 1.01 Manner of Submission of the Tender

The tender shall be divided into 03 parts as follows:-

- a) Part A: This part Comprises of Cost of Tender document & EMD, NIT No. & date marked with Part A.
- b) **Part B:** This part Comprises of Technical and Commercial details, consent on terms & conditions of NIT along with copy of System generated **acknowledgement-slip** for Online submission of sealed price bid etc. marked with (Part-B) Techno-Commercial Bid, NIT No. & Date (*In hard copy*)

## Note: Part A & Part B shall be submitted in hard copy at following address:

DGM (P&C)

Bokaro Power Supply Co. (P) Ltd. Hall No.M-01, Old ADM Building

Ispat Bhawan, Bokaro Steel City – 827001

Ph: 06452 240380, Tel: 8986874098

c) Part C: Online sealed Price Bid through URL: http://www.buyjunction.in

#### The process of submission of Online Price bid is as detailed hereunder-

- Step 1: Type http://www.buyjunction.in in the internet explorer.
- Step 2: Click on Login (present on Top right side of the Page)
- Step 4: Click on View Live Auctions and Tenders.
- Step 5: In the right side open/global tenders link will be displayed.
- Step 6: Click on the link for the above mentioned tender link present under Open tenders
- Step 7: Click on new user if you are not registered in buyjunction earlier. Click on Existing user incase you have already registered in buyjunction earlier. Existing users can login with their user id and password.

**Please note** foreign bidders are required to select their bidding currency from the drop down available before proceeding further (where ever applicable).

#### **New Users:**

Steps to get your User Code and Password

- 1. Click on the required tender link under "Open Tenders"
- 2. Choose your Auction currency in-case any option is coming to select currency. Click on "New User"
- 3. Fill up the "Registration Form" and click on "Submit". All fields marked with (\*) are mandatory fields.
- 4. On submitting the filled-up registration form, an auto generated email will be sent to the email address you have mentioned in the registration form containing your User Code and Password.
- 5. Changing of password on first login is compulsory.
- 6. On receipt of the User Code and Password you become an **Existing User.** Now follow the steps of existing user to login to the auction site.

#### **Existing Users**

- 1. Click on the required tender link under "Open Tender"
- 2. Click on "Existing User".
- 3. Log in with your existing user code and password for placing your bid.
- 4. Read through the "Bidding Procedure" to proceed further for bidding.

#### **Bidding Procedure**

After logging in with your user id and password you have to accept the "Auction Terms".

#### Steps to accept the "Auction terms":

- 1. Click on "Auction Terms".
- 2. Then click on "View term without DSC"
- 3. Click on the relevant auction terms appearing under "**Term** "column.
- 4. Select the check box on the left-side of the relevant auction terms.
- 5. Click on the button besides "Accept".
- 6. Then click on "Submit".
- 7. A message will be displayed to you mentioning your acceptance to terms for auction.
- 8. It is mandatory to accept the terms of online bidding in order to proceed for submission of bid.

#### **Steps to Submit Price Bid**

- 1. Click on "Bids."
- 2. Then click on "Live Auction."
- 3. Put your login password as transaction password
- 4. Select the auction id and click on add to watch list.
- 5. Now the bidding screen is visible.

#### 6a. For Template Bidding

- 1. Click on **Icon "T"** on left column of bidding screen (Which will appear separately **for each lot**).
- 2. A template form will open where you need to fill up the price & click on evaluate at the bottom
- 3. If you want to quote the evaluated price then click on "confirm".
- 4. After clicking on the confirm button of the template window, your price will appear in the "New Bid" box.

## 6b. For Non-Template Bidding

- 1. Fill your Price in the "New Bid Box" visible on the bidding screen.
- 2. Select the check box at the extreme left of the bidding screen
- 3. Click on "Submit" button placed at the bottom left of the screen.
- 4. Bid once placed will have to be honoured.
- 5. You will see "Bid Accepted" in the "Result" column. This indicates that your bid is accepted and registered in the system.

#### Steps to take a print-out of the receipt

- 1. Once you have placed your bid, to download Bid Receipt, kindly click on "Download".
- 2. Then click on "Bid Receipt for Open Tender".
- 3. Select the auction to generate receipt.
- 4. Take print out of the same market-wise (Term List)/ item-wise (Auction list).

#### Note:

- 1. Current price, Market status, Start Bid Price, Bid Decrement, Effective Price will not be available.
- 2. Time remaining for the event to close will be shown under the Bid Summary screen.
- 3. For any clarification on the bidding process please contact
- Mr. Manish Nandwana \_ 9163348165\_ manish.nandwana@mjunction.in
- Ms. Monalisa Shaw \_ 9163348297 \_ monalisa.shaw@mjunction.in

#### Mr. Sumit Kumar Das – 8873002750 - sumit.das@mjunction.in for Bokaro Office

A copy of System generated **acknowledgement-slip** for Online submission of sealed price bid to be submitted along with Techno-commercial Bid.

1.01.1 A & B part should be sealed in separate envelopes, clearly superscribing on the top of each envelope the relevant part number and description along with NIT reference and date of opening and submit all the parts simultaneously in another sealed envelope clearly superscribing NIT reference and date of opening.

#### 1.02 Tender Validity Period

The tender shall be valid at least for 120 (One hundred twenty) days from the date of opening.

#### 1.03 General

- i) Tenderer's are requested to visit site for actual assessment of the job before submission of their offer.
- ii) The tender rates shall be written in English, both words and figures. In the case of any discrepancy between the words & figures of the rates quoted, the rates expressed in words shall be taken as correct. In the case of discrepancy in the Unit Rate and Amount, Unit Rate will govern.
- iii) All pages of the tender documents, conditions, specifications & all enclosures must be signed with seal of the company at the lower left hand corner by the tenderer before submission of the tender.
- iv) If the intending tenderer is a Firm or Company, then they shall, in the forwarding letter, mention the number and names of all the partners & shall sign before submitting the same, unless the Power of Attorney holder has specifically been authorized in this respect.
- v) If any tenderer withdraws his tender before its acceptance or refuses within a reasonable time without giving any satisfactory and acceptable explanation thereof, the tenderer shall be disqualified for making any tender of the BPSCL for a minimum period of one year and the Earnest Money will be forfeited.

#### vi) Handling of Earnest Money:

- a) Earnest Money will be refunded to the un-successful tenderer after finalisation of tender and no interest will be paid for the same. Bidders are requested to provide Bank Details for refund of EMD.
- b) The amount of Earnest money will be adjusted against Security Deposit only in case of successful Tenderer.
- vii) In case the date of tender opening happens to be holiday, the tender will be opened on the next working day at the same time.
- viii) <u>Any conditional offer or offer having deviations from our qualifying requirement, specification & instruction sheets is liable to be rejected.</u>
- ix) BPSCL reserves the right either to reject any/all the tenders without assigning any reason thereof.

## **General Terms and Conditions**

- 2.01 Bidders are requested to visit the site before submission of the bid to get acquainted with actual site condition.
- 2.02 You will have to follow and observe the safety & statutory requirements.
- 2.03 You will have to fully responsible for any sort of unsafe activity of your workmen.
- 2.04 All working personnel should have proper safety certificates issued by BPSCL before start of work.
- 2.05 Supervision of the work has to be carried out by the agency.
- 2.06 Work is to be carried out as per instruction & satisfaction of the Engineer-In-Charge.
- 2.07 Rates are to be quoted on firm price basis. Any conditional offer is liable to be rejected.
- 2.08 In case of any documents/information submitted by the bidder(s) found to be false or containing any misrepresentation of having any fraudulent declaration in it then in such eventuality legal action (including cancellation of contract, banning of business dealing, forfeiture of EMD, criminal proceedings etc.) as deemed fit may be initiated by BPSCL against the bidder.

#### 2.09 Payment Terms:

90% of contract value will be paid on pro-rata basis on progressive jobs duly certified by Engineer In-Charge and balance 10% will be retained as security deposit which will be released after **three** (03) months of satisfactory execution of work.

The expression satisfactory execution of the order shall mean fulfillment of all obligation arising out of and the guarantees stipulated in the contract. In default at satisfactory execution of the order the security deposit shall be forfeited to the BPSCL.

Any penalty for which the successful tenderer shall be found liable or any liquidated damages which shall be payable to the BPSCL in terms of the Contract, shall also be recoverable by the BPSCL from the Security deposit. If such security deposit will not be adequate for the purpose of liquidating the amount of penalty and/or damages as contemplated, the amount in excess thereof shall be deducted from any sum or sums which may be due or may become due to the successful tenderer from the BPSCL on any account whatsoever.

Notwithstanding what has been stated above if the successful tenderer shall have duly performed all his obligation under and the guarantees stipulated in the contract and observe all the terms and conditions thereof and no penalty shall have been recoverable from him and / or the BPSCL shall not have suffered any damages whatsoever, then security deposit shall be refunded, on receipt of a certificate from the Engineer in - charge that there is no claim against the Successful tenderer under the Contract.

- 2.10 Contractor will produce medical fitness certificate for his workers prior to CLC clearance for working at height. Height passes to be obtained from safety department.
- 2.11 You will have to strictly adhere to the provision of various labour laws including payment of bonus Act 1965.
- 2.12 You will have to pay Rs.4/- extra to the working persons as per BPSCL rules above minimum wage of one day.
- 2.13 Offer is to either type written or by handwritten and in no case partly type written and partly hand written. No corrections, overtyping shall be permitted without duly authenticated.
- 2.14 Tenders shall be accompanied by a copy of latest IT Return submitted, Service Tax Registration No. (if applicable) of the Indivdual / Party/Firm submitting the Tender.
- 2.15 Paying authority –In charge (F&A), BPSCL.
- 2.16 Tenderers shall quote their firm rates and no negotiations will be held except with the lowest tenderer, if required.
- 2.17 In accepting the order you are understood to accept to all responsibilities for completing the work in all respect.

- 2.18 Where a claim of Service Tax is preferred and admitted, the tenderer must satisfy that he is a registered contractor under Service Tax Act and possesses a Certificate of Registration in the firm's name in which the service is made and shall in proof thereof, while submitting bills for payment, furnish the number, date and other particulars of such Certificate.
- 2.19 The manpower (labour and Supervisor) deployed for completion of the job and for compliance of work & safety of the workmen should be adequate. However the compliance and completion of the job cannot be restricted to labour supply but on the actual execution of the job to be certified by the Engineer In charge.
- 2.20 <u>VDA Clause</u>: During operation of the contract, if there is an upward revision of minimum wages, VDA by the appropriate Government, the Contractor shall be entitled to reimbursement of such additional amount on actual basis subject to production of documentary evidence. The base date shall be the Bid opening date OR Revised offer date (in case of negotiated prices)

#### 2.21 Work accident:

- **a.** You will be totally responsible for the safety of the workers employed by them. In the event of any work-accident, major or minor, your representative you must take care of the injured person immediately and provide him the required treatment as suggested by the doctor. The injured person may be admitted to BGH for the treatment by paying the charges as demanded by the hospital authority.
- **b.** You shall be fully responsible for making payment of compensation to your own workmen or to those of your sub-contractor in respect of any accident or injury occurring to them. BPSCL will in no way be responsible for it and will remain indemnified against all such claims of compensation in such cases

#### 2.22 SUBMISSION OF BANK GUARANTEE FOR QUOTING UNWORKABLE RATE:

if a tenderer quotes unworkable rates i.e. if the quoted price is less than the lower limit of the estimated price and is considered for placement of order, the party will be asked to justify the rate quoted and will have to give Performance Guarantee Bond (in addition to the Security Deposit) in the form of Bank Draft/Bank Guarantee. The amount of Performance Guarantee Bond will be equal to the difference between lower limit of estimated price and quoted price of the tenderer. Earnest Money of the tenderers who refuse to give Performance Guarantee Bond will be forfeited and they will not be considered for taking participation in any kind of Tender for next Six (06) months from the date of issue of letter to the Defaulter Firm, if order / contract is not finalised from the present tender.

2.23 **FORCE MAJEURE**: Vendors / Contractor shall not be considered in default if delay occurs due to cause beyond their control such as acts of God, natural calamities, civil wars fire, strike, frost, floods, riot and acts of unsurpassed power. Only those causes which have duration of more than seven days shall be considered in force majeure clause. In the event of delay due to such clause the delivery / completion period will be extended for a length of time equal to the period of force majeure of at the option of owner order may be cancelled without any liability what so ever on the part of the owner.

#### 2.24 RATE FINALIZATION:

Rates shall be finalized through Reverse auction or offline negotiation with **L-1 bidder** at the discretion of BPSCL. The bidder shall submit their price bid though URL http://www.buyjnction.in. BPSCL reserves the right to re-launch the reverse auction or process the case on the basis of ranking derived from on-line price bid submitted by bidders at the time of submission of techno – commercial bid. The bidders have to submit their acceptance as per enclosed format at **Annexure** – **VIII & IX** along with their technocommercial bid. The schedule and details of reverse auction event shall be communicated by our service provider (**M/s MJunction Service ltd.**) to the techno-commercially accepted bidders.

- 2.25 The Parties should clearly indicate their prices firm in all respects till execution of the work order.
- 2.26 In case of asking any variation on any account whether sales tax or Service tax (wherever applicable) will not by treated as firm price on that account and hence parties should state everything clearly.
- 2.27 **Special Instruction:** Tender will be opened on **17.04.2017 at 12.15 PM.** If it is declared a holiday by BPSCL then in the next working day at the same time in the presence of Tenderer's Authorized Representatives, who wish to be present.

## **Scope of works:**

**1. PREVENTIVE MAINTENANCE**: to provide assistance in the following jobs:

#### I. 6.6 KV Oil Circuit Breakers (OCBs) & Bulk Oil Circuit Breakers (BOCBs

- a. Cleaning of insulators, pole chambers and other parts of the breaker. Replacement of defective parts. Checking of oil. Topping-up tested oil up to required level. Replacement of turbid oil in pole chambers. Arresting oil leakage.
- b. Checking of spring charging mechanism, auxiliary contact, indications, Signals, mechanical interlocks etc. and rectifying the defects.
- c. Checking ON/OFF operations both manually and electrically with breakers in 'TEST' Position. Rectifying the defects. Meggering.
- d. Measuring contact resistance of each pole of the breakers. Proceeding for medium repair if the contact resistance is higher than the permissible value, or, if there is any other major internal problem of the breaker.

#### II. Vacuum Circuit Breakers (VCBs) /6.6 KV

- a. Thorough cleaning of insulators, surge arrestors, vacuum chambers and other parts. Repair / replacement of defective parts.
- b. Checking of vacuum seals, spring charging mechanism, auxiliary contacts. Indications, signals, position locks, mechanical / electrical interlocks & rectifying the defects.
- c. Checking ON/OFF operations both manually and electrically with breaker in 'Test Position' rectifying the defects. Meggering.
- d. Measuring contact resistance of each pole of the breaker. Proceeding for replacement of vacuum chamber (as decided by Engineer in-charge), or, if there is any other major internal problem of the breaker.

## III. LT Air Circuit Breakers (ACBs) (AC & DC)

- a. Cleaning of insulators and other parts. Replacement of defective parts.
- b. Checking of resetting mechanism, auxiliary contact, indications, signals, door locks, position locks, limit switches mechanical / electrical interlocks etc & rectifying the defects.
- c. Checking ON/OFF mechanism & operations of breaker in Test position, if possible. Rectifying the defects. Meggering.
- d. Measuring contact resistance of each pole of the breaker. Proceeding for medium-repair, if the value is higher than permissible limit, or, if there is any other major problem of the breaker.
- IV. <u>HT and LT Isolators (6.6 KV, 415 V AC & 220 V DC)</u>: Thorough cleaning of Isolators and other parts. Replacement of insulators. Jaw-contacts or other parts, if found defective. Checking of door locks, position locks and other interlocks & rectifying the defects. Meggering. Revival / replacement of the isolators subject to breakdowns.
- V. <u>LT & HT Potential transformers (PTs)</u>: Thorough cleaning of PTs insulators and other parts. Repair or replacement of the defective parts. Tightening of connections and checking of Switches and fuses etc. Rectifying the defects. Meggering.
- VI. <u>Current Transformer (CTs) / 6.6 KV& 415 V:</u> Thorough cleaning of CTs insulators and other parts. Repair or replacement of defective parts. Tightening of connections. Rectifying the defects. Meggering

#### VII. Switch Gear Cubicles (6.6 KV& 415 V)

- a. Thorough cleaning of mini-buses, insulators, cables, cable glands and other parts including panel walls and panel doors.
- b. Tightening of HT and LT connections. Checking switches, indications and limit switches etc.

- c. Checking of sealing of doors, covers & cable entry etc. Checking of door locks, mechanical/electrical interlocks, hinges, ventilation & cooling etc. of the cubicles. Rectifying the defects coming to knowledge.
- d. Revival of cubicles subject to breakdown.
- VIII. <u>Generator Excitation Panels</u>: Through cleaning of insulators and other accessories of the cubicles. Replacement of defective parts. Tightening of connections and rectifying defects.Revival of cubicles subject to breakdown. Providing assistance of job executing agency in replacing the panel subject to renovation.

#### IX. Generator Field Breakers

- a. Thorough cleaning of Insulators, fixed & moving contact, arc chutes and resistor etc.
- b. Checking of ON/OFF mechanism, contact pressure, auxiliary contacts, indications and signals. Repair / replacement of defective parts. Meggering.
- c. Measuring contact resistance. Proceeding for medium-repair, if the value is higher than the permissible limit, or, if there is any other major problem in the breaker.
- d. Revival / replacement of the breaker subject to breakdown.
- X. <u>HT and LT Sections of Indoor Switch Gear (6.6 KV & 415 V)</u>: Thorough cleaning, blowing and tightening of section buses, droppers, knife switches in droppers from LT sections, support insulators and replacement of insulators, if required. Meggering and noting down the IR value of sections of each phase. Revival of sections subject to breakdown.

#### XI. Indoor Transformers (6.6 KV/ 440V)/ (Sovtol filled transformers)

- i. Through cleaning and blowing of transformer tank, its bushing, fittings, radiators and terminal box.
- ii. Checking and tightening of power circuit connection on HV & LV side.
- iii. Checking oil leakage from tank-cover, bushing, valves and radiators etc. and doing the needful to arrest the leakage.
- iv. Checking oil level and topping up, if needed.
- v. Checking the functioning of temperature indicators.
- vi. Checking for proper earthing connections at all points.
- vii. Meggering and nothing down the IR values.
- viii. Checking for the availability of right type of fire-extinguishers near the transformers.
- ix. Revival of the transformer subject to breakdown
- x. Providing assistance in replacing the transformer subject to renovation.

#### 2. MEDIUM REPAIR: to provide assistance in the following jobs: -

#### i. 6.6 KV Oil Circuit Breakers (OCBs) & Bulk Oil Circuit Breakers (BOCBs

- a. Dismantling of poles of breakers after draining of oil. Attending to defects of fixed and moving contacts, arc chambers, arms, Jaw-contact, spring charging mechanism, spring charging motor, oil seals, gaskets, 'O' rings, Split pins, insulating cranks and contact roller etc. Replacing the parts which are beyond repair.
- b. Re- assembling the poles and other mechanism of the breaker with associated fittings as per norms and standard procedures. Filling up fresh tested oil in poles up to required level. Checking manual operation. Adjusting contact-travels to values as per norms.
- c. Checking electrical operation and mechanical interlocks. Checking oil leakages. Rectifying the defects.
- d. Measuring contact-travels, contact resistances and also doing Meggering etc. Recording the results.
- e. Revival / replacement of the breaker subjected to breakdown.

#### ii. Vacuum Circuit Breakers (VCBs) / 6.6 KV

- a. Dismantling the poles of breaker. Replacing vacuum chambers in case of loss of vacuum, defective surge-arrestors and insulators. Repairing or replacing the defective parts, auxiliary contact assembly, plug-sockets or any other parts not found working properly.
- b. Re-assembly the breaker with all fittings as per norms and standard procedure.
- c. Checking manual/ electrical operations and mechanical interlocks. Meggering and recording the results.
- d. Measuring of the contact-resistance of the VCB and logging the rest results.
- e. Revival / replacement of the breaker subjected to breakdown.

#### iii. Air Circuit Breakers (ACBs) / 220 V DC, 415 V and Generator field breakers

- a. Dismantling the poles. Repairing or replacement of main contact (fixed and moving), auxiliary contacts, arc-chutes, springs, contact-arms, jumpers, jaw-contacts or any other part, if found defective.
- b. Re-assembling the poles with all fittings as per norms and standardprocedure. Adjusting contact pressures, checking manual/ electrical operations and all interlocks. Rectifying the defects.
- c. Measuring contact resistances, and also doing Meggering and logging the test-results.
- d. Revival / replacement of the breaker subjected to breakdown.

#### 3. <u>TEMPERATURE MONITORING AND DEFECT RECTIFICATION</u>: Temperature of HT

incomer-feeders and all the load-feeders will have to be regularly monitored using infrared camera. If any hot point is detected. It is to be set right at the earliest taking the shut-down so that, it does not get converted into a measure breakdown. Thermography –survey results, location of the hot point, if any and the defect rectification measures are to be recorded properly.

**4.** TROUBLE SHOOTING IN ALL THREE SHIFTS: If any trouble arises in the Indoor switchgear equipments, it is to be solved immediately. Readiness for taking up a job should always be there round the clock. Hence, working-personnel will have to be posted by you in all the three shifts covering 24 hours on all days including Sundays & Holidays, so that, the defects-rectification job could be started immediately as soon as the problem arises. A back-up group will always be ready even in odd hours to tackle the problem, if the front- line repair-man feels any difficulty in solving the problem.

#### 5. ATTENDING TO BREAKDOWNS

- 1) If a breakdown occurs, the expert attending-group will have to be present at the occurrence-site and report to the control engineer (electrical section) within half an hour.
- 2) The affected portion is to be isolated under the guidance of control engineer (electrical section) and breakdown-repair works is to be started immediately after receiving work-permit.
- 3) After attending to the break down, the system is to be normalized back again under the guidance of control engineer (electrical section).
- 4) During breakdown, the repair-job is to be continued round the clock until the affected part is attended and normalized back.

#### 6. CLEANING OF FLOORS AND PANELS

- 1) The floors of S/G rooms must be cleaned regularly using brooms, dusters, brushes & vacuum cleaners first and later on by wet mopping using detergents.
- 2) The S/G panels should be cleaned from outside using the vacuum cleaners and marking cloth regularly.
- 3) The inside of LT S/G panels should be cleaned using vacuum cleaners after taking permission from control engineer (electrical section) and adopting safety measures against possible hazards as and when possible. The inside of HT S/G panels should be cleaned only during shutdown period.

- 4) All dust entry points inside the panels/ cubicles and finally inside the S/G rooms should be located and plugged.
- 5) Cleaning of S/G rooms will include cleaning of floors, doors, windows, window glasses and removal of cobwebs etc.
- 6) Dust and garbage accumulated due to cleaning activities should be disposed off in a dust bin made of HDPE material and kept at different places for such purposes only.
- 7) All the dust bins will have tobe taken to a central garbage disposal yard and will be emptied there regularly
- 8) If floors are found damaged here and there on a smaller scale and posing problems in sweeping and mopping, it should be repaired using suitable material.
- 9) The level of cleanliness maintained must be of high order.

#### 7. HOUSEKEEPING

- 1. Scrupulous materials found littered and garbage generated during the repair- work must be mopped and disposed-off immediately in the dust-bin or at remote barren place.
- 2. Spares, consumables, tools, tackles, kits and instruments etc all must be kept nicely arranged on racks and in almirahs.
- 3. The final outcome of all the activities pertaining to Housekeeping should be:
  - a) The panels are to be maintained neat and clean.
  - b) The S/G rooms look tidy and arranged and also well illuminated
  - c) Sufficient numbers of fire fighting equipments are available inside S/G rooms.
  - d) No seepage of water and ingress of dust into the S/G rooms
  - e) The S/G rooms are manned by duty-post man round the clock and entry of unauthorized persons completely stopped.

#### 8. MAINTAINING VENTILATION AND COOLING SYSTEM IN PROPER WORKING ORDER

The contractor will have to maintain the air pressurizing, ventilation and cooling systems in proper working condition to maintain the desired level of temperature and cleaning in the S/G rooms all the time. If any defect or shortcoming is detected in this system, that is to be repaired / replaced / modified and made alright. Under this head we have got 03 nos. of Air intake fans (for 1 KV reactor cooling), 30 nos. of exhaust fans and 04 nos. of motors of tube axial fans (for pressuring 6.6 KV S/G rooms and some other places).

- 7. **PAINTING OF PANELS AND LABELLING:** All the S/G Panels should be spray painted and labeling done correctly, whose shining surface have become dull or got damaged so that, they always look new and bright. The required paints and thinner will be supplied by BPSCL.
- **10.PROVIDING ASSISTANCE IN DOING RETROFITTING OF VCBs:** You will provide assistance to job executing agency in doing retrofitting of new VCBs in place of old OCBs/ VCBs (6.6 KV / 440 V) and LT ACBs.

## 11. <u>SETTING RIGHT CABLE-CONNECTION PROBLEMS</u>

- i. Setting right power cable connection problems pertaining to connections, lugging and taping etc. in the switchgear panels.
- ii. Carrying out connection / disconnection and replacement/ repair of control cables pertaining to indoor switchgear equipments.

# 12. <u>PROVIDING ASSITANCE TO 'OPERATION-GROUP' IN CARRYING OUT</u> 'SHUTDOWN'AND'NORMALIZATION' ACTIVITIES.

You will provide assistance to 'Shift-operation' group under the leadership of shift in charge of MCB / ECR-II in isolating and normalizing the equipments which are taken for repair.

#### 13. MAINTENANCE AND REPAIR OF EARTHING GRID

- 1) Carrying out regular inspection and maintenance of Earth-pits, Electrodes and Earth-Strips and doing repair as per the requirement.
- 2) Measuring earth-resistance values and noting them down in tabular form.
- 3) Ensuring earth-resistance values within norms by doing treatment with water and salt.

#### 14. LOGGING AND RECORD- KEEPING

- 1. You will maintain job-progress record on daily, monthly and annual basis.
- 2. Check-list will have to be filled-up pertaining to each equipments as and when that equipment is taken for maintenance and repair
- 3. Maintenance and repair records of all the equipments of indoor switchgear system along with technical specifications will have to be maintained.
- 4. An updated record of spares requirements and their available stock will have to be maintained and also maintain their consumption-pattern.
- 5. All the records must be systematic and computerized so that, it may be retrieved and presented any time on demand.

#### **SPECIAL TERMS & CONDITIONS:**

1. <u>Electrical License and ISO certification</u> The bidder has to submit a self-attested copy of valid (up-to-date) Electrical License for conducting contractual jobs of electrical nature, or proof of application for renewal of the same.

#### 2. Guidelines regarding performance of work

- i. The contractor will perform the subject work in accordance with the guidelines contained in the work order, technical specifications of equipments/ devices, IS codes of practice, and the instructions of the Engineer-In-Charge.
- ii. All incidental items of work not shown or specified but reasonably implied and found to be necessary for successful completion of the work shall be deemed to be included in the scope of work at no extra cost to BPSCL.
- iii. In case of any doubt or contradiction regarding jobs, the decision of the Engineer- in-charge will be final and abiding.

#### 3. Test certificates of safety equipments

- i. The electrical safety appliances like electrician's shoes, HV insulated gloves and insulated mats, etc, should be used only after getting the same tested at a reliable testing laboratory on a regular basis.
- ii. All other safety appliances like helmets and safety belts, etc, must be purchased from standard companies and used only after getting them tested.
- iii. Tools used by electricians must be of electrical grade, properly insulated and tested.
- **4.** <u>Supervision of work:</u> Supervision of work on site on daily basis shall have to be carried out by your supervisor and you will be fully responsible for any unsafe, indecent, illegal incidents caused by the employees.

#### 5. Work accident

- i. The contractors will be totally responsible for the safety of the workers employed by them. In the event of any work-accident, major or minor, the representative of the contractors must take care of the injured person immediately and provide him the required treatment as suggested by the doctor. The injured person may be admitted to BGH for the treatment by paying the charges as demanded by the hospital authority.
- ii. The contractor shall be fully responsible for making payment of compensation to its own workmen or to those of its sub-contractor in respect of any accident or injury occurring to them. BPSCL will in no way be responsible for it and will remain indemnified against all such claims of compensation in such cases.
- **6.** Work permit: As the area of work is highly sensitive with respect to safety hazards, the responsible supervisor / engineer of the contractor must take proper work-permit, shutdown clearance and other instructions from the Engineer in-charge, daily before start of the work
- 7. <u>Compliance with various Labour laws and Electricity rules</u>: The contractors will have to strictly comply with the provisions of various labour laws, electricity rules, Workmen Compensation Act, EPF and ESI rules, etc, as applicable for working at site of Power Plant, BPSCL. The contractors shall be directly responsible for all the consequences arising from their non-compliances and BPSCL will remain indemnified against all such implications pertaining to them.
- **8.** <u>Load- lifting equipments</u>: All the load lifting equipments like slings, ropes, D-shackles and safety belts, etc, must be tested by an authorized agency at regular intervals and their test- certificates obtained.

#### 9. Input by BPSCL (free of cost)

Following materials will be supplied by BPSCL, free of cost:-

- a) Transformer oil to be used in OCB.
- b) Mobile Crane, Truck and Fork Lift.
- c) Compressed air, electricity and water.
- d) All types of spares needed to be replaced during the repair work of transformers and breakers, isolators & other equipments of HV Switchgear.
- e) Industrial gases for carrying out gas-cutting and welding.
- f) Gaskets, insulating varnish, grease, sealants, lubricants, Transformer-oil, 'O' ring, rubber chord, oil seals, nuts-bolts, paints, thinner, etc.
- g) General and special purpose welding electrodes and brazing rods.
- h) Steel plates, pipes, angles and channels, GI pipes, etc.
- i) Power and control cables, lugs, glands. HT tape and lug-crimping tools etc.
- j) Machining facilities as available in area Repair Shop of BPSCL.
- k) Different sizes of simple and telescopic platform ladders.
- **10.** <u>Assistance in analysis of faults:-:</u> If any break-downs occurs, it is to be analyzed to find out its root cause. Once the cause is identified, its remedial measure is also to be thought out and incorporated in consent with the engineer in charge so that, a similar break-down does not occur again.

#### 11. Job competence of working personnel

- i. Supervisors of the executing agency must have familiarity with the power system practices and the types of equipments as used in power generation and distribution network in a Thermal Power Plant.
- ii. Supervisors and technicians, deployed for doing the jobs, should have enough job experiences and competence in all the relevant areas. Your working personnel must have a thorough knowledge of carrying out maintenance and repair jobs of LT Motors, HT & LT switch gears and others covered by scope of the work. So they are responsible to perform the jobs successfully. Their workmanship should be of high skilled grade.
- iii. You should employ supervisor shaving good experience of working at systems of appropriate voltage level in AC & DC.

#### 12. Job planning and scheduling

- i. After assessing the total quantum of work, job planning & scheduling will have to be done so that, job fulfillment target is achieved in all areas.
- ii. Planned shutdown of any particular equipment, line, etc, may not be available on some particular day due to unfavorable plant condition. Planning is to be re-scheduled accordingly.
- **13.** <u>Preservation of Spare Parts</u>: Spares as well as the dismantled parts of equipments will have to be kept safely and preserved properly, maintaining a systematic record of them. Spare conservation is to be done regularly.
- **14.** Workmanship guarantee If a repair fails within the next six months, the contractors will be held responsible for it and the contractors shall have to re-do the repair, free of cost.
- 15. <u>Regular Inspection and monitoring of Equipments in the system</u>: All the equipments and devices installed in the work area covered by scope of work, are to be inspected regularly by the Engineers / Supervisors / Technicians engaged by the contractor, and various technical parameters are to be noted. Monitoring of conditions and technical parameters are to be taken-up for planning of shutdown / maintenance schedules for healthy up-keep of equipments.

- **16.** <u>Guidelines by BPSCL Engineers</u>: The job is to be done under the guidelines of BPSCL officer in charge. In case of any dispute regarding the quality of the job the decision of officer in charge of BPSCL will be final and abiding. The job completion certificate will be issued by him.
- **17.** <u>Type of Work:</u> The present job is not an independent type of job and is only for assisting the maintenance and repair job of electrics of LT & HT indoors switch gear area of TPP and CHP portion of Power Plant. The job will have to done strictly as per detailed instruction of officer in charge of BPSCL.

#### 18. You shall maintain all records/ register/ return/ cards such as:-

- i) Register of workmen employed by you
- ii) Employment card
- iii) Muster Roll
- iv) Register of wages-cum-muster roll
- v) Submission of return
- vi) Order book

#### 19. Conditions for Manpower deployed

- a.) You have to provide minimum indicative manpower required for the job is as follows: -Supervisor (ND) 01 No.; SW 05 Nos.; SSW 02 Nos.; USW 05 Nos on regularly excluding weekly OFF.
- b.) All workmen deployed for the work will have to follow and observe the safety & statutory requirements. They should attend safety training of BPSCL successfully.
- c.) The contractors will have to ensure proper medical fitness of the employees employed by him and will produce medical fitness certificates for them from a registered medical practitioner prior to clearance for working at height.
- d.) Proper use of safety appliances, personnel protection equipments (including safety helmet, hand gloves, safety goggles, safety shoes, full body harness, etc, whatever required), by the manpower deployed, should be ensured.
- 20. Penalty Charges: You will be exposed to following types of penalty charges:-
  - 1. If the manpower deployed is less than that given in the minimum manpower clause (clause 20. a) a penalty @ of Rs. 100.00 per mandays along with existing labour wage will be deducted from the payment.
  - 2. If there is any loss of production of power plant due to shortage of manpower or any other cause attributable to you or employees deployed by you, an amount of Rs. 5000/- will be charged as penalty.
  - 3. If you are found violating the guidelines and polluting the environments, you may be charged anything between Rs. 500/- to 1000/- as penalty.
  - 4. For gross violation of safety requirements, you shall be liable for penalty as detailed in the "Safety Clause" given below.
  - 5. While executing the routine job, if delayed beyond the stipulated time, a penalty of Rs. 500/- to Rs. 1000/- may be charged.
  - 6. If shortage of tools, tackles, consumables, measuring and testing instruments and safety equipments is detected, Rs. 100/- to Rs. 500/- will be charged as penalty.
  - 7. If any accident takes place due to gross violation of safety requirements, you will be solely responsible for the same, and you will have to bear the cost of medical treatment of the injured person, and pay the required compensation as per clause no. 7 of Special Terms & Conditions (Annexure II).
  - 8. If a breakdown occurs due to either poor workmanship or some sort of negligence in doing a job properly, a penalty of Rs 1000/- to Rs 5000/- will be charged.

- 9. If the cleaning of the switchgear rooms and panels are not found up to the mark. A penalty of Rs 500/- to Rs 1000/- will be charged.
- 10. Your employee must be competent enough to execute the work without damaging anything. If such damage takes place, cost of spares and its replacement-cost will be recovered from you.
- 11. In additional to above, if any other act of omission, negligence and lack of expertise is detected in the responsibility areas, it will expose you to penalty charges of Rs. 5000/- for each case.
- **21. <u>SAFETY CLAUSE</u>**: Without prejudice to the right conferred by the clause for stoppage of work for violation of safety requirements, contractor shall be liable for penalties mentioned below:-
  - 1. Up to Rs. 5000/- by DGM (Safety)/ Head of Safety Engg. Department / Head of the Department where work is being done for 1<sup>st</sup> violation of safety norms, non-use of PPEs (Personal Protective Equipments) like safety shoes, hand gloves, safety helmets, goggles, etc as per works requirements by the contractor or his workers. This condition is applicable in case of violations of Road Safety norms also.
  - 2. Fine up to Rs. 20,000/- on 2<sup>nd</sup> violation as mentioned in Safety Clause no. 1 above.
  - 3. The contractor shall be debarred for one year / deregistered from taking up further contractual work in BPSCL from the date of issue of debarring / deregistering order on 3<sup>rd</sup> violation as mentioned in Safety Clause no. 1 above.
  - 4. Fine up to Rs. 10,000/- for violation in use of Full Body Harness by the contractor or his workers for working at height (above 1.8 meters from immediate floor).
  - 5. Fine Rs. 25,000/- (Minimum) to Rs. 50,000/- (Maximum) for serious injuries and disabilities caused by violations as mentioned in Safety Clause no. 1 & 4 above.
  - 6. Independent of the above, contractor shall be fined Rs. 1,00,000/- (Rs. 1 Lakh) or more and debarred / deregistered from taking up further contractual work in BPSCL from the date of issue of debarring / deregistering order in case any fatal accident occurs due to violations as mentioned in Safety Clause no. 1 & 4 above.

## PRICE BID/ FORMAT

#### **Special Instruction –**

- 1. In the event of a L1 Bidder backing out prior to placement of order, in addition to forfeiture of EMD the bidder should be suspended for a period of six months from the date of issue of suspension order
- **2.** Breakup of quoted unit **LC** (**Landed Cost** ) **excluding service tax** rate shall be submitted by the bidder. In case of refusal of L1 bidder to submit price break up, the bidder shall be suspended for a period of six months from the date of issue of suspension order.
- 3. Price Basis L1 bidder will be decided on lowest Landed Cost excluding service tax Basis.

**Summary of Schedule of Qty: Summary of Schedule of Qty:** 

Description	Duration	Total Amount (Rs.)
Assistance in Maintenance and Repair jobs of Electrical Equipments	01 year	
belonging to LT & HT Indoor Switch Gear area of TPP (including		
CHP area) of Power Plant		

#### **⇒** Price Break-up:

Sl.	Description of Jobs	Rate/ Month (Rs.)	Amount for 01 (one) year (Rs.)
1.	Assistance to Maintenance & Repair jobs of HT (6.6 KV) breakers consisting of MOCBs & VCBs in TPP 6.6 KV Switch Gear and CHP Switch Gear.		
2.	Assistance to Maintenance & Repair jobs of HT (6.6 KV) cubicles and HT isolators.		
3.	Assistance to Maintenance & Repair jobs of LT (AC & DC) ACB <sup>s</sup> including Generator Field Breakers and CHP area.		
4.	Assistance to Maintenance & Repair jobs of LT (AC & DC) Isolators.		
5.	Assistance to Maintenance & Repair jobs of LT (AC & DC) Cubicles including Generator Excitation panels.		
6.	Assistance to Maintenance & Repair jobs of LT & HT PT <sup>s.</sup>		
7.	Assistance to Maintenance & Repair jobs of LT & HT CT <sup>s</sup> (Lots).		
8.	Assistance to Maintenance & Repair jobs of HT Section buses including CHP area.		
9.	Assistance to Temperature monitoring and defect rectification of all the HT Feeders.		
10.	Assistance to maintenance and repair of 40T, 41T, 42T, 43T & 44T as per the requirement.		
11.	Assistance to Maintenance & Repair jobs of HT (6.6 KV) Bulk Oil Circuit Breakers (BOCBs) in CHP Switch Gear.		
12.	Assistance to Housekeeping in switchgear rooms and cleaning of floors and panels of all the switchgear rooms and their vicinity areas.		
13.	Assistance to Maintenance & Repair jobs of Exhaust fans in switchgear rooms.		
14.	Assistance to Painting and labeling of LT & HT switchgear panels as per the requirement.		
15.	Assistance to Maintenance & Repair jobs of AC & DC LT buses in TPP Switch gear and CHP area.		

16.	Assistance to Setting right cable-connection problems as per the		
10.	requirement.		
17.	Assistance to Operation Group in carrying out shutdown and		
	normalization activities pertaining to switchgear system.		
18.	Assistance to Maintenance & Repair jobs of 'Earthing Grid'		
10.	pertaining to Indoor switchgear system.		
19.	Assistance to Logging, Record keeping and record making of		
	all the activities.		
		Total	
Rupees only			

Note: Service Tax extra as applicable

Signature with seal of tenderer

# **ANNEXURE - VI**

# **Notarized Affidavit**

	on/daughter of Shriears resident of
(name of the firm/company).  (ii) I confirm that all documents submi	(designation/authority) in M/s
Solemnly affirmed & declared before me by Deponent(s) who is/are identified by	The declaration made herein above are true to the best of our knowledge, information and belief  signed at
	Deponent(s)

CHECKLIST TO BE FILLED BY CONTRACTOR EXCEPT REMARKS:- All documents which is require for fulfill the qualifying requirement/ Eligibility criteria are to be submitted along with tender in serial order (clearly mention page no.) and the tenderer must fill the checklist of Annexure-V

#### **CHECKLIST 1- OF DOCUMENT SUBMITTED BY TENDERER**

Sl.No.	Document	Submit/ Not Submitted	Page No.	Remarks by BPSCL
1.	Valid work order			
2.	Completion Certificate			
3.	Partnership/ Proprietor			
4.	EPF			
5.	ESI			
6.	Latest ITR			
7.	* Service Tax Regn. No.			
8.	Turnover/ PL Sheet			
*If the agency is not under the preview of service tax then please write Not applicable (N.A.).				
Total numbers of pages in Techno-commercial Bid				

# CHECKLIST-2 [PLEASE TICK (√) THE ONE WHICH IS APPLICABLE AND CUT (X) ANOTHER] 1. All document as per NIT and Checklist 1 Submitted ( ) Not submitted ( ) Not submitted ( )

#### **DECLARATION OF TENDERER:-**

Signature of tenderer with seal

(To be submitted on Supplier's Letter Head)

# Format for Acceptance of General Terms & Conditions, Commercial Terms and all other Terms of the Reverse Auction

We			_ (Contractor Name)
having registered office at			_ (Address)
agree to all the Commercial,	General & other Te	rms & Conditions listed	in the
NIT No			
dated			
for the work of		_(subject work) through I	Reverse Auction.
We confirm that we are in a p participate in the Reverse Aud	·	•	ven in NIT/RFQ. We agree to
We nominate an executive, w	hose details are given	below, to put the bids on	our behalf.
The details of the person author	orized to bid on our be	half is as follows.	
Name & Designation	:		
E-mail ID	:		
Contact phone nos.	:		
Address	:		
(Signature & Seal)			
Place	:		
Date	:		

# Format for submitting last quoted prices

(To be submitted on Company Letter Head of the Bidder)

# (To be sent within 30 mins of conclusion of the Reverse Auction)

To,	
mjunction services 1 <sup>st</sup> Floor, Tata Cent 43, Jawaharlal Neh Kolkata – 700 071	rre
Fax: 033 – 2288 32	279
Ref: Reverse Auct	tion forfor Bokaro Power Supply Co. (P) Ltd. held on
	we hereby confirm our Market wise last quoted prices in the Reverse Auction held or for Bokaro Power Supply Co. (P) Ltd., Bokaro Steel City.
Market No.	Last Quoted Price
We also confirm the Auction.	nat we will submit item wise price break-up, within two working days from the date of Reverse
Signature :	
Name :	
Designation :	
Date :	

#### **ENVIRONMENT, HEALTH AND SAFETY**

# EHS (Environment, Health and Safety) Clause for contracts where overall site is under BPSCL control Contractor's Responsibilities

The contractor shall during the entire term of contract undertake to perform the following obligations relating to environment, health and safety:-

- 1. Ensure that your workforce is not exposed to asbestos or asbestos containing atmosphere.
- 2. Take suitable control measures to ensure that the workers are protected from dust emission.
- 3. Monitor and ensure that the working area is free from any toxic gas, vapour and fume. Take adequate measures to reduce level of concentration below permissible limit. Exposure to any particular toxic gas, vapour or fume shall not exceed the maximum permissible limit prescribed in local regulation for any particular period of time. Ensure adequate ventilation and no immediate danger to life and health of personnel working at site.
- 4. Ensure that there is no flammable atmosphere and uncontrolled fire hazard in and around the work place. In case it is required to work in flammable atmosphere, implement safe working procedure and suitable control measures in order to work safely.
- 5. Ensure that the workers are protected from excessive noise and heat. Take adequate measures to reduce noise/heat level below the permissible limit.
- 6. Ensure safe access and egress in and around work place. Ensure proper maintenance of Platforms, staircases, ramps etc. Special care and all safety measures should be taken while working at height. Roof work and access to roofs must not be undertaken without prior permit.
- 7. All Personal Protection Equipments supplied by the contractor should be of internationally recognized standards. All tools and tackles bought by the contractor for use during the contract period should have proper and valid certification by competent authority.
- 8. All lifting equipments, tools and accessories provided by BPSCL should be maintained and returned back in sound condition after the completion of contract period.
- 9. Ensure that the illumination in and around workplace and access areas are maintained properly. Make sure to switch off the light, fan and air conditioners after use.
- 10. The contractor must ensure that all machinery and equipments are provided with earth fault circuit breakers at all times when using electrical leads. Use of electrical tape for temporary repair is prohibited.
- 11. Guards and covers for equipments/machineries are to be provided where ever necessary.
- 12. Gas cylinders shall be securely stored, transported, identified and used in line with legislation and EHS requirements.
- 13. Fire extinguishers and other fire fighting equipments provided in different locations should never be misused.
- 14. Contractor must ensure optimum use of water with minimum wastage.
- 15. Contractor shall also ensure that the work area is kept clean, tidy, & free from debris. The contractor is also fully responsible for protection of ground and underground from pollution.
- 16. Identify and highlight potential hazards / risks existing.
- 17. Ensure suitable corrective actions are implemented for identified issues.
- 18. Provide adequate emergency and first-aid facilities and it should be available in all shifts.
- 19. All workers should be trained and communicated about the onsite emergency and evacuation plan.
- 20. All equipments and plant should be maintained in safe condition.
- 21. The Contractor and their Personnel admitted to site must conduct themselves in an orderly and safe manner and conform at all times to the EHS Requirements. Fighting, engaging in horseplay, being under the influence of or possessing alcohol or drugs, gambling, soliciting, stealing, immoral or otherwise undesirable conduct is not permitted and shall not be tolerated. Upon knowledge of such conduct, BPSCL shall exclude the concerned person from the site and take all other appropriate measures as deemed necessary. BPSCL reserves the right to perform random drug and alcohol tests.
- 22. The Contractor shall immediately notify BPSCL of any environmental incident, injury, illness, near-miss, unsafe condition or practice and any loss or damage to property, including incidents related to the Contractor Personnel. An investigation report assessing the root cause, corrective action, and preventative action shall be submitted by the Contractor to BPSCL within 24-hours of the incident's occurrence.